


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. H3. 7383/21Date : 27/03/2021

It is certified that an inspection team headed by DILEEP.B
HEALTH INSPECTOR. (Name of Officers
with designation) from KANNUR MUNICIPAL CORPORATION (Name of
Department/Office) inspected the SFS ENGLISH MEDIUM SCHOOL
VETTLAPPALLY VAYAL, THANA.P.O, KANNUR (Name & Address of
the School) on 19.03.2021 and found that the SFS ENGLISH MEDIUM
SCHOOL, VETTLAPPALLY VAYAL, THANA (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 2021 - 2022

Signature with Seal : 
Name : Dhanabalan A.K.
Designation : Health Supervisor


HEALTH SUPERVISOR
KANNUR MUNICIPAL CORPORATION

To

The Principal
SFS English medium school
Vettilappally Vayal, Thana
(Name & Address of the Institution)




JAISMON FRANCIS
PRINCIPAL
SFS English Medium School
School Code: 76179
Vettilappally Vayal, Thana P.O., Kannur-670012, Kerala
Email: kannursts@gmail.com


Manager
S.F.S. ENGLISH MEDIUM SCHOOL
VETTLAPPALLY VAYAL
THANA.P.O.
KANNUR - 670012.




**KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT**

Report No -		Date : 3/4/2021			
Customer Name and Address SFS English Medium School, Vettilapalli Vayal, Thana.P.O., Kannur -12		1. Date of receipt	: 30/03/2021		
		2. Sampling done by	: Sample done by party		
		3. Sample Code	: 08-21 (18)		
		4. Source of Sample	: Pipe water		
		5. Sample quantity	: 1 lit + 100 ml		
		6. Test performing dates	From : 30/03/2021 To: 31/03/2021		
Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Colour	HAZEN	IS 3025 (part 04) -1983 (Reaffirmed 2017)		-
2	Odour		IS 3025 (part 5) -2018		-
3	Turbidity	(NTU)	IS 3025 (part 10) -1984 (Reaffirmed 2017)	1	0.7
4	pH		IS 3025 (part 11) -1983 (Reaffirmed 2017)	6.5 to 8.5	7.0
5	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14) -2013 (Reaffirmed 2019)		105.1
6	Acidity	(mg/litre)	IS 3025 (part 22) -1986 (Reaffirmed 2019)		BDL
7	Alkalinity	(mg/litre)	IS 3025 (part 23) -1986 (Reaffirmed 2019)	200	32.0
8	Sulphate (as SO ₄)	(mg/litre)	IS 3025 (part 24) -1986 (Reaffirmed 2019)	200	10.0
9	Total Dissolved Solids (TDS)	(mg/litre)	IS 3025 (part 16) -1984 (Reaffirmed 2017)	500	78.83
10	Total Hardness (as CaCO ₃)	(mg/litre)	IS 3025 (part 21) -2009 (Reaffirmed 2019)	200	24.0
11	Calcium (as Ca)	(mg/litre)	IS 3025 (part 40) -1991 (Reaffirmed 2019)	75	4.81
12	Magnesium (as Mg)	(mg/litre)	IS 3025 (part 46) -1994 (Reaffirmed 2019)	30	2.92
13	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) -1988 (Reaffirmed 2019)	250	23.86
14	Fluoride (as F)	(mg/litre)	IS 3025 (part 60) -2008 (Reaffirmed 2013)	1	BDL
15	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) -2003 (Reaffirmed 2014)	1	BDL
16	Nitrate (as NO ₃)	(mg/litre)	IS 3025 (part 34) -1988 (Reaffirmed 2019)	45	BDL
17	Total Coliforms	CFU /100 ml	IS 1622:1981; Reaffirmed 2003		Nil
18	E.Coli	CFU /100 ml	IS 1622:1981; Reaffirmed 2003		Nil

Remarks: All the tested parameters are within limit.

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory.

Authorised By  Bacteriologist

Authorised By  Chemist


* End Of Report *

* BDL - Below Detection level

Issue No: 1

Issue Date : 14.09.2020

JAISON FRANCIS
PRINCIPAL
SFS English Medium School
School Code: 76179
Vettilapally Vayal, Thana P.O., Kannur-670012, Kerala
Email: kannursfs@gmail.com


Manager
S.F.S. ENGLISH MEDIUM SCHOOL
VETTELAPALLY VAYAL
THANA P.O.
KANNUR - 12

SR. SANITARY CHEMIST
QUALITY CONTROL REGIONAL LAB
KERALA WATER AUTHORITY
KANNUR-12